

District Level Water Testing Laboratory, Chatra Jathrahi Bagh, PHED Office, Chatra-825401

Email: dlwtlchatra@gmail.com



TC-11132

Test Report

Report No:	2302/TAN/414	Issue Date- 23-02-2024		
Issued To: (Name & Address	D.A.V. PUBLIC SCHOOL,NTPC,NORTH KARANPURA, TANDWA, CHATRA	Group: Drinking Water		
of Customer)	JHARKHAND 825103	Discipline: Chemical		
Date of Start	23-02-2024	Sampling: Not done by laboratory		
Analysis:		Sample Received: 23-02-2024		
		Environmental Condition of laboratory Temperature: 23 °C Humidity: 42 %		

SI. No.	Parameter	Unit	Result	Method Reference	Specification as per BIS 10500:2012 (Second Revision) Amendment - June 2015	
					Acceptable Limit	Permissible Limit (In Absence of Alternate source)
1	pH at 25∘C		7.21	APHA 23 rd Edition 2017-4500-H ⁺ B,	6.5 – 8.5 No relax	No relaxation
	*	- 3		(Electrometric Method)		140 (Claxation
2	Turbidity	NTU _.	0.12	APHA-23rd Edition 2017-2130-B,	1	5
				(Nephelometric method)		
3 .	Total Dissolved	mg/L	33	APHA 23 rd Ed.2017-2540 C, (Total	500	2000
	Solids			Dissolved Solids Dried at 180°C)		
4	Total Hardness as	mg/L	32	APHA-23 rd Edition 2017-2340-C	200	600
	CaCO ₃			(EDTA Titrimetric method)		
5	Total Alkalinity	mg/L	24	APHA-23 rd Edition 2017-2320-B,	200 600	
	as CaCO ₃			(Titration Method)		600
6	Calcium as Ca+	mg/L	8.01	APHA-23 rd Edition 2017-3500-Ca-B,	75 200	
				(EDTA Titrimetric Method)		200
. 7	Magnesium as	mg/L	2.91	APHA-23 rd Edition 2017-3500-Mg-B,	30	
	Mg+			(Calculation Method)		100
8	Fluoride as F mg/	mg/L 0.50	0.50	APHA 23 ^{rd.} Ed.2017-4500 F ⁻ C,	1.0	1.50
			0.30	(Ion selective electrode method)		
9	Colour	HU ·	5	Visual comparison	5	15
10.	Odour		Agreeable	Observation	Agreeable	Agreeable

Notes: -

- The results listed refer only to the tested sample and applicable parameters.
- This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
- This report cannot be reproduced, except when in full, without the written permission of the Lab In-charge
- All disputes are subjected to the Chatra Jurisdiction.
- ♦ BDL=Below Detection Limit.

-End of the Report-

Principal
DAV Public School
NTPC North Karanpura

Manager
DAV Public School
NTPC North Karanpura

D.W.&S. Division, Chatra