

PHONES: 00-11-42785500
Fax : 91-11-42785512



CIVIL ENGG. DIVN
E-Mail: gdc.delhi@airtelmail.in
E-Mail: delhiced@gdcl.in
Website: www.gannondunkerley.com

GANNON DUNKERLEY & CO. LTD.

Regional Office: B-228, OKHLA INDUSTRIAL AREA, PHASE – 1, NEW DELHI-110020

OUR REF: GDC/NTPC/KAN/23-24/2576

Date: - 23.08.2023

To,
AGM (CCD)
National Thermal Power Corporation
North Karanpura STPP (3X660 MW)
Tandwa, Dist-Chatra, Jharkhand

Kind Attn: Mr. N D Pandey – AGM (CCD)

Ref.: LOA No. CS-4410-364-9-CS-LOA-6625 Dt. 04.01.2018 for Permanent Township Package.

Subject: Lightning protection system At DAV School.

Dear Sir,

We would like to bring kind notice that we have fixed lightning arrestor at DAV School NTPC, Tandwa.

Protocol for Value of Earth resistance lightning protection system of ~~DAV~~ School enclosed herewith for your ready reference.

Thanks & Regards,
For Gannon Dunkerley & Co. Ltd.

Santosh Kumar
(Sr. Manager - Projects)

Rajesh
28/9/23
राजीव त्रिपाठी/Rajeev Tripathi
अपर महाप्रबंधक (विद्युत उद्योग)/Addl. G.M. (EE)
उत्तरी करणपुरा एन.टी.पी.सी. / North Karanpura STPP
एन.टी.पी.सी. लिमिटेड, टंडवा, जिला NTPC Limited, Tandwa, Chatra

Rajesh Kumar
Sr. Manager (EE)
NTPC - NKSTPP.

EP-1 EP-2
 Value of Earth Resistance = 1.02Ω 0.19Ω
 (Lightening Protection System of DAV School)
 NTPC NK TANDWA
 CHATRA (JHARKHAND)



Earth value
 22/8/22
 NTPC
 CHATRA
 22/8/22



22/8/22
 NTPC
 CHATRA

SACHIN KUMAR
 DGM (EE)
 NTPC LIMITED
 NK Tandwa
 Chatra, Jharkhand

